

**The BA368C** is an intrinsically safe multi-function instrument which may be programmed to perform a host of counting and timing functions. Easy to use menus allow the instrument to be configured as a counter, timer, tachometer or as a clock. Both of the inputs will operate from 2-wire proximity detectors, switch contacts, magnetic pick-offs, open collector or voltage pulses. Optional alarm/control outputs further extend the many applications.

**Counting** may be from one or both inputs. The pulses at each input can be added to, or subtracted from each other, and the result may be scaled to provide a display in engineering units. Alternatively, pulses on one input can increment or decrement the total count depending upon the state of the other input. From two inputs electrically 90° out of phase (quadrature), the BA368C can display the direction of movement and position of a shaft or a cable. The total display may be reset to zero via the instrument controls or by a remote contact closure.

As a timer the BA368C may be started and stopped by one or both inputs or from the instrument push-buttons. Elapsed or remaining time may be displayed in hours, minutes and seconds, or in just hours and minutes. When fitted with optional control outputs the instrument can control any process which is required to operate for a fixed time.

Rotational speed may be measured using the tachometer function which will display revolutions per second, minute or per hour. The instrument contains a run-time counter which can show the total operating time of the monitored machinery on the second display. When fitted with optional alarms, over and under speed warnings can be generated.

**Configuration as a digital clock** enables time to be displayed in twelve or twenty four hour format within a hazardous area. The instrument may operate as a standalone clock, or may be synchronised via the reset terminals with an external reference. Two optional control outputs enable hazardous or safe area loads to be turned on and off at pre-set times twice in each twelve or twenty four hour period. **Control and programming** of the BA368C is performed via four front panel tactile push-buttons which 'click' when operated. All the programme functions are contained in easy to understand menus which may be protected by a user definable security code. To simplify calibration the scaling factors employ floating decimal points.

The front panel is a robust, easy to clean Noryl moulding sealed with a non-reflective, scratch resistant polyester membrane. A captive neoprene gasket provides an IP65 seal between the enclosure and the panel.

ATEX intrinsic safety certification permits installation in all gas hazardous areas throughout Europe. The two inputs may be connected to a wide range of certified sensors and all the outputs are separate galvanically isolated intrinsically safe circuits. FM intrinsic safety and non incendive approvals allow the BA368C to be installed in the USA.

**Backlighting** is available as an option to improve readability when the BA368C is installed in a poorly illuminated area. High efficiency amber LEDs provide an even glow to enhance display contrast.

**Optional alarms/control outputs** provide two galvanically isolated solid state outputs each of which is a separate intrinsically safe circuit and complies with the requirements for *simple apparatus*. Almost any certified intrinsically safe load such as a solenoid valve or sounder may be controlled by these outputs.

**Pulse and 4/20mA outputs** may be provided as an option to operate remote equipment. Each output is galvanically isolated and certified as a separate intrinsically safe circuit.

**Free of charge programming** and calibration to customers requirements is performed prior to despatch, although the BA368C can easily be reconfigured on-site without the need for any test equipment or programming aids.


# BA368C

## Counter, timer, tachometer, clock

Intrinsically safe for use in all gas hazardous areas

- Separate 8 digit and 16 digit displays
- Two inputs
- Intrinsically safe ATEX & FM certification
- 144 x 72 DIN enclosure with IP65 front panel

Optional: Display backlight Alarms Pulse and 4/20mA outputs







BEKA associates Ltd. Old Charlton Rd. Hitchin, Hertfordshire, SG5 2DA, U.K. Tel. (01462) 438301 Fax (01462) 453971 e-mail sales@beka.co.uk www.beka.co.uk

## **SPECIFICATION**

#### Power supply Voltage

#### Current

#### Inputs A and B

Switch contact Closed Open Proximity detector Magnetic pick-off Voltage pulse Low High Open collector Closed Open Frequency switch contact other inputs

#### Display

Type Primary Decimal point Secondary Decimal point

#### Remote reset

#### Programmable functions Counter

Total scale factor Grand total Rate scale factor

#### Time

Maximum duration Direction

#### Tachometer

Rate scale factor

Clock External synchronisation

#### Intrinsic safety

#### Europe ATEX Code Certificate number Location

USA FM

Standard

Code

File No

Standard Code

File No

#### Environmental

Operating temperature Storage temperature Enclosure EMC Immunity Emissions

Mechanical

Terminals Weight

Accessories Alarms/control outputs Outputs

On Off

Display backlighting

Re-transmitted pulse

TR Automatyka Sp. z o. o.

ul. Lechicka 14 ; 02-156 Warszawa

4/20mA output Voltage drop Typeset scale card The BA368C must be powered via a Zener barrier or galvanic isolator 10V min between terminals 1 and 2. 12mA max., plus proximity detector currents when used.

Less than 1000 Greater than 1kΩ 2-wire NAMUR 40mV peak to peak typical

Less than 1V Greater than 3V; 30V max

Less than  $2k\Omega$ Greater than 10kΩ

100Hz max 5kHz max. Reduced to 2kHz for quadrature input

Liquid crystal 8 digits 14mm high; 1 of 7 positions or absent; colons for h:m:s 6 diaits 9.5mm high 1 of 5 positions or absent; colons for h:m:s

Contact closure with resistance less than 1kΩ

A; A+B or A-B; A direction controlled by B A and B Quadrature (90° out of phase) Adjustable between 0.001 & 99999999 10<sup>16</sup> max count Adjustable between 0.001 & 99999999

Elapsed time displayed as hh:mm:ss or

hh:mm 99 hours:59 minutes: 59 seconds Up or down

Revolutions displayed per sec, per min or per hour. Adjustable between 0.001 & 99999999

Set time displayed in 24 or 12 hour format Once per 12 or 24 hours

Group II, Category 1G Ex ia IIC T5 ITS01ATEX2004 Zone 0. 1 or 2

3610 Entity CL I; Div 1; GP A, B, C & D T4 @ 60°C 3022309

3611 Nonincendive CL I; Div 2; GP A, B, C & D T4 @ 60°C 3022309

-20 to 60°C (Certified for use at -40°C) -40 to 85°C Front IP65: rear IP20 In accordance with EU Directive 2004/108/EC. Less than 1% error at 10V/m Undetectable above background noise. Class B equipment

Screw clamp for 0.5 to 1.5mm<sup>2</sup> cables. 0.6kg

Two independent outputs. Isolated solid state switch Less than 5Ω +0.6V Greater than 180kΩ Certified as simple apparatus LED backlight powered from 28V  $300\Omega$ Zener barrier or galvanic isolator. Pulse sink certified as simple apparatus

Galvanically isolated current sink 5V max

Blank scale card fitted to each instrument, can

Tel. (+48 022) 886 10 16 Fax. (+48 022) 846 50 37

## DIMENSIONS (mm)


#### Recommended panel cut-out


DIN 43 700

Panel cut-out

## 138.0 +1.0/ -0.0 x 68.0 +0.7/ -0.0


To achieve an IP65 seal between the instrument and the panel 136.0 +0.5/-0.0 x 66.2 +0.5/-0.0 Four panel mounting clips must be used





Terminals for optional backlight and alarms are shown in outline

## **TERMINAL CONNECTIONS**



protection: front panel switches can not be operated.

Counter; timer; tachometer or clock.

Proximity detector; switch contact; magnetic

pick-off, open collector or voltage pulse.

\* See accessory datasheet for details please specify

### HOW TO ORDER

Model number Configuration Inputs

Calibration information

#### Accessories Display backlight Alarms/control outputs Re-transmitted pulse output 4/20mA output Scale card

Tag number

please specify . Backlight Alarms Pulse output 4/20mA output Legend required

Settings required #

BA368C

# If calibration information is not supplied, instrument will be conditioned as a counter; input A + input B; for open collector inputs; rate & total scale factors of 1.

Legend required

09

www.trautomatyka.pl biuro@trautomatyka.pl